

Classification Report

Number	19-002257-PR05 (NW-H05-05-en-01)
Owner	VITROFORM Sp. z o.o. Cichawa 152 32-420 Gdów Poland
Product	Laminated safety glass (LSG)
Designation	Shipping name: VSG 66.2 PVB
Details	Overall dimensions (W x H): (876 x 1938) mm, material: Float glass ExtraClear®, Glass configuration: float glass 6 mm / PVB 0.76 mm / float glass 6 mm, Thickness: 12.76 mm, measured thickness: 12.53 mm
Special features	-/-

Result

Classification Pendulum Test according EN 12600



Class: 1 - (B) - 1

Basis *)

EN 12600:2002-11

*) and corresponding national versions (e.g. DIN EN)

Test report: 19-002257-PR05 PB-H05-05-en-01

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and detailed results given relate solely to the tested/described specimen.

This test does not allow any statement to be made on further characteristics of the present structure regarding performance and quality, in particular the effects of weathering and ageing. The classification will be valid as long as the product remains unchanged and the above bases have not changed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

23.01.2020



Frank Zirbel, Dipl.-Ing. (FH)
Head of Testing Department
Security/Safety Testing



Khalid El Harda, Dipl.-Ing. (FH)
Operating Testing Officer
Security/Safety Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: C1D-BD6EA